



**ELECTRICAL REQUIREMENTS:**

- \* ALL CONDUIT WILL BE RIGID, HEAVY WALL GALVANIZED STEEL
- \* MINIMUM CONDUIT SIZE WILL BE 3/4" DIAMETER
- \* ALL FLEXIBLE CONDUIT WILL BE "SEALTITE, WITH WATERTIGHT CONNECTORS
- \* ALL CONTROL WIRING SHALL BE MULTIPLE CONDUCTOR RATED 600 VOLTS. 90' #14AWG MINIMUM CODE TYPE XHHW-2

(PI) FIELD INSTALL  
 QUOTATION SHOULD INCLUDE  
 PHYSICALLY MOUNTING THESE COMPONENTS

▨ WIRE TRAY  
 — CONDUIT